

[Provisional Translation Only]

This English translation of the original Japanese document is provided solely for information purposes. Should there be any discrepancies between this translation and the Japanese original, the latter shall prevail.

March 5, 2019

Issuer

Ichigo Green Infrastructure Investment Corporation ("Ichigo Green," 9282) 1-1-1 Uchisaiwaicho, Chiyoda-ku, Tokyo Representative: Mami Nagasaki, Executive Director www.ichigo-green.co.jp/en

<u>Asset Management Company</u> Ichigo Investment Advisors Co., Ltd. Representative: Hiroshi Iwai, President Inquiries: Hiroto Tajitsu, Head of Administration Tel: +81-3-3502-4854

Solar Power Generation and CO2 Reduction Data – February 2019

FY19/6									
	No. of Solar Power Plants	Panel Output (MW)	Forecast Power Generation (kWh) (A) ¹	Actual Power Generation (kWh) (B)	Difference (B) - (A)	CO2 Reduction (kg-CO2) ²			
July	15	29.43	3,418,117	3,624,652	+206,535	2,392,270			
August	15	29.43	3,478,494	3,622,499	+144,005	2,390,849			
September	15	29.43	3,033,437	2,803,042	-230,395	1,850,007			
October	15	29.43	2,865,438	2,895,669	+30,231	1,911,141			
November	15	29.43	2,174,038	2,405,927	+231,889	1,587,912			
December	15	29.43	1,993,313	1,686,609	-306,704	1,113,161			
January	15	29.43	2,111,049	2,074,486	-36,563	1,369,160			
February	15	29.43	2,377,363	2,156,570	-220,793	1,423,336			
March	_	_	3,128,232	-	_				
April	_	_	3,327,554	_	_	_			
May		_	3,459,631	_	_	_			
June		_	3,106,749	_	_	_			
Full Year		_	34,473,421	_		_			

Explanation

February solar power generation was 2,156,570kWh, 9% below forecast, due to a belowaverage number of productive daylight hours on the Pacific coast of Honshu and in Okinawa.

¹ Forecast Power Generation is a 50% probability mean annual production forecast (P50 forecast), calculated by an independent, third-party technical consulting firm, that serves as the base forecast for each solar power plant's operating plan.

² CO2 reduction is calculated as 0.66kg CO2 per kWh.

February 2019								
Solar Power Plant	Panel Output (MW)	Forecast Power Generation (kWh) (A)	Actual Power Generation (kWh) (B)	Difference (kWh) (B) - (A)				
Ichigo Kiryu Okuzawa	1.33	124,096	133,917	9,821				
Ichigo Motomombetsu	1.40	108,685	83,755	-24,930				
Ichigo Muroran Hatchodaira	1.24	100,242	98,183	-2,059				
Ichigo Engaru Kiyokawa	1.12	83,823	57,358	-26,465				
Ichigo Iyo Nakayamacho Izubuchi	1.23	95,860	82,328	-13,532				
Ichigo Nakashibetsu Midorigaoka	1.93	200,441	161,154	-39,287				
Ichigo Abira Toasa	1.16	106,839	83,299	-23,540				
Ichigo Toyokoro	1.02	112,120	104,623	-7,497				
Ichigo Nago Futami	8.44	564,275	577,070	12,795				
Ichigo Engaru Higashimachi	1.24	91,279	56,263	-35,016				
Ichigo Takamatsu Kokubunjicho Nii	2.43	195,347	177,099	-18,248				
Ichigo Miyakonojo Yasuhisacho	1.44	125,788	104,777	-21,011				
Ichigo Toyokawa Mitocho Sawakihama	1.80	170,882	155,205	-15,677				
Ichigo Yamaguchi Aionishi	1.24	98,054	90,142	-7,912				
Ichigo Yamaguchi Sayama	2.35	199,624	191,390	-8,234				
Total	29.43	2,377,363	2,156,570	-220,793				

Power Generation by Solar Power Plant

Ichigo Green discloses realtime solar power production and CO2 reduction data for each Ichigo Green solar power plant at <u>www.ichigo-green.co.jp/en/portfolio</u>